

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2275

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2275 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2275** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2276

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2276 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2276** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2296

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2296 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2296** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2307

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2307 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2307** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2308

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2308 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2308** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2315

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2315 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2315** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2316

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2316 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2316** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2317

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2317 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2317** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2318

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2318 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2318** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2319

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2319 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2319** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2320

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2320 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2320** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2321

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2321 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2321** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2322

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2322 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2322** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2323

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2323 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2323** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2324

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2324 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2324** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2325

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2325 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2325** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2326

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2326 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2326** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2327

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2327 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2327** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2328

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2328 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2328** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2329

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2329 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2329** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2330

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2330 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2330** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2331

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2331 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2331** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2332

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2332 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2332** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2333

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2333 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2333** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2390

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2390 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2390** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2391

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2391 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2391** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2392

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2392 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2392** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2393

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2393 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2393** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2394

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2394 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2394** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2395

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2395 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2395** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2396

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2396 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2396** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2397

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2397 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2397** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2398

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2398 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2398** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2399

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2399 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2399** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2400

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2400 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2400** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au

6th April 2023
Ref No: Flagstone City Stage 5B_Lot 2401

SEE Civil Pty Ltd
108 Siganto Drive
Helensvale QLD 4210

CERTIFICATE OF CONTROLLED LEVEL 1 FILLING

LOT 2401 – FLAGSTONE CITY STAGE 5B

Australian Soil and Concrete Testing was commissioned by SEE Civil Pty Ltd to provide earthworks inspection and testing services on a 'Level 1' basis in accordance with the requirements of AS 3798-2007 '*Guidelines on earthworks for commercial and residential developments*'.

Fill was placed on the development between 09/09/2021 and 28/02/2023.

Based on the observations made by Australian Soil and Concrete Testing and the test results obtained during construction the structural fill placed on allotment **2401** is considered to have been carried out in general accordance with AS3798-2007 and is considered to be Controlled Fill as defined in AS2870 – 2011 '*Residential Slabs & Footings*'.

Full details of the inspection and testing conducted is included in our report Ref No: **1053_SEE Civil_Level 1_Flagstone City Stage 5B**.

Please do not hesitate to contact me if you have any queries.

Yours faithfully



Jason Mckenna
Laboratory Manager

ASCT Brisbane South
jason.mckenna@asct.com.au