



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 365**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 365 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 366**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 366 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 367**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 367 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 368**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 368 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 417**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 417 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 418**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 418 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 419**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 419 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx





FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 420**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 420 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx





FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 421**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 421 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 422**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 422 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 423**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 423 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 424**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 424 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 425**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 425 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx



FORM SGS/CF/09I

29 June 2015  
Job No. SGS/15/039

Naric Civil Pty Ltd  
PO Box 150  
REDBANK QLD 4301

**RE: CERTIFICATE OF CONTROLLED FILLING**  
**LOCATION: RIVERBANK, STAGE 9 BULK EARTHWORKS - MORAYFIELD**

**LOT NO. 426**

Fill was placed on the above allotment during the construction of the above mentioned estate.

SGS Australia Pty Ltd was commissioned on this project to provide earthworks inspection and testing services on a Level 1 basis as detailed in Clause 8.2 of AS 3798-2007 "Guidelines on earthworks for commercial and residential developments". Full details of the inspection and testing program are provided in the SGS Australia Pty Ltd report (Form SGS/CF/10), Job No. SGS/15/039 dated 29/06/15.

Based on the test results and site inspections, SGS Australia Pty Ltd concludes that the fill foundation to a depth of not less than 150mm and placement of compacted fill on Lot 426 as defined laterally in the attached drawing is considered to comply with the requirements of Table 5.1 of AS 3798 and the project specification.

All fill in the areas defined in the attached drawing, within the time frame of our inspection and testing programme between 09/03/15 and 03/06/15 (excluding topsoil placed subsequent to completion of controlled filling) is considered to be "Controlled Fill" in accordance with AS 2870 "Residential Slabs and Footings" (Clause 6.4.2 (a)) and AS 3798.

Unless otherwise stated, Level 1 certification does not address any other geotechnical issues which may be relevant to building construction and serviceability.

A full geotechnical site investigation/classification and foundation design for the specific ground conditions should be carried out by suitably qualified and experienced personnel, prior to building when the house type and location is known. This service can be provided if required, by contacting SGS Australia Pty Ltd on 3881 3511.

Yours faithfully,

**SGS AUSTRALIA PTY LTD**

**G Kosanovic**

**CL Barclay**  
RPEQ 8846

encl. Drawing showing lateral extent of controlled filling

SGS-15-039-LC-01.docx