

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BS**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 409 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 409 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BR**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 410 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 410 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BQ**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 411 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 411 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BP**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 416 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 416 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BO**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 417 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 417 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BN**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 418 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 418 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BM**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 419 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 419 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BL**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 420 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 420 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.



**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BK**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 421 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 421 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p + 61 3 9464 4617**  
**f + 61 3 9464 4618**

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BJ**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 422 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 422 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BI**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 423 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 423 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BH**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 424 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 424 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BG**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 425 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 425 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**11 April 2017**

**GS4050.2 BF**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 426 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 426 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p + 61 3 9464 4617**  
**f + 61 3 9464 4618**

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 AT**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 427 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 427 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p + 61 3 9464 4617**  
**f + 61 3 9464 4618**

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 AU**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 428 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 428 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.



**p + 61 3 9464 4617**  
**f + 61 3 9464 4618**

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 AV**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 429 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 429 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p + 61 3 9464 4617**  
**f + 61 3 9464 4618**

**13 Brock Street, Thomastown**  
**Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 AW**

**PEET Botanic Village c/-**  
**GPR Consulting**  
**Suite 217, 202 Jells Road**  
**WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE**  
**LOT 430 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 430 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 AX**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 431 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 431 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 AY**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 432 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 432 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 AZ**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 433 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 433 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p + 61 3 9464 4617**  
**f + 61 3 9464 4618**

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**27 March 2017**

**GS4050.2 BA**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 434 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 434 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AA) dated 27 March 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BW**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 439 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 439 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.

**p** + 61 3 9464 4617  
**f** + 61 3 9464 4618

**13 Brock Street, Thomastown  
Victoria, Australia,3074**

**ABN 31 105 704 078**



**15 May 2017**

**GS4050.2 BX**

**PEET Botanic Village c/-  
GPR Consulting  
Suite 217, 202 Jells Road  
WHEELERS HILL, VIC**

**RE: CONTROLLED FILL CERTIFICATE  
LOT 440 ACACIA ESTATE, STAGE 3B AND 4, BOTANIC RIDGE, VICTORIA**

Ground Science Pty Ltd wishes to advise the prospective owner/builder that the construction of Lot 440 located at the Acacia Estate in Botanic Ridge involved the placement and compaction of controlled fill through Level 1 procedures on nominated areas. We were engaged by GPR Consulting (acting on behalf of PEET Botanic Ridge) to perform Level 1 Inspection and Testing for the controlled fill placement in accordance with AS3798 'Guidelines on Earthworks for Commercial and Residential Developments' (2007) on this property. The depth and location of the controlled fill and results of compaction control testing are detailed in the Ground Science Level 1 report (ref: GS4050.1 AB) dated 15 May 2017. We certify that all fill placement completed on this lot as detailed in our report complies with the requirements of AS3798 (2007).

The purpose of performing Level 1 Inspection and Testing is to ensure the quality of the filling process and to minimise the costs of extensive testing. The engagement of a Geotechnical Inspection & Testing Authority (GITA) allows the contractor to perform his role in the construction of the filling operation while the GITA monitors the quality control process of the operation. The visual observations of thorough processors and work practises by the contractor allows the GITA to approve the subsequent placement of fill without having to wait for the completion of testing and the extended time it takes to receive a test result. The GITA will however, carry out random spot checks of the filling operations throughout the days production as confirmation that the placement procedures and the fill moisture content is appropriate. At the end of a days production, the GITA will sign off the completed works as satisfactory.

While moisture conditioning of fill sources aids in the ease with which compaction is achieved, it is not necessarily a physical characteristic that determines if the placed fill is acceptable. Ground Science adopts a best practice policy with stripped base soils and all fill placements to be suitably moisture conditioned. This aids in creating a homogenous soil moisture and limits abnormal moisture changes for footing systems constructed on the fill platform. Creating a consolidated platform of which is similar to surrounding natural conditions is the primary aim of the Level 1 processes and assists in minimising the occurrence of differential ground movements to footing structures. The full report may be viewed or obtained from the estate developer's sales office should the need arise.